

# SKG-IKOB PRODUCTCERTIFICATE

## 514.312.01

Date of issue: 03-09-2018



### Certificate holder

iLOQ Oy  
Yrttipellontie 10  
FL-90230 Oulu  
T: +358 (0) 40 3170 200  
E: info@iloq.com  
I: www.iloq.com



### Declaration of SKG-IKOB

This certificate has been issued on the basis of BRL 3104 in accordance with the SKG-IKOB Regulations for Attestation, Certification and Inspection.

SKG-IKOB declares that the by or on behalf of the certificate owner produced building hardware product:

#### oval cylinder

delivered under logo / brand:

#### Iloq

delivered under type- and / or article number:

#### C10S.1.SB.NL , C10S.10.SB.NL

meets class 2 STER according BRL 3104 and NEN 5089: 2009 if the product is indelibly marked with the SKG mark, as shown above.

For SKG-IKOB

A handwritten signature in blue ink, consisting of a stylized, cursive script.

ir. H.A.J. van Dartel  
Certification manager

Verify at [www.sterrenwijzer.nl](http://www.sterrenwijzer.nl) if this certificate is still valid and actual.  
This certificate contains 2 pages.

CERTIFICATE

SKG-IKOB Certificatie  
Poppenbouwing 56  
4191 NZ Geldermalsen

Postbus 202  
4190 CE Geldermalsen

T 088-2440100  
info@skgikob.nl  
www.skgikob.nl

# SKG-IKOB PRODUCTCERTIFICATE

iLOQ Oy  
Number: 514.312.01

page 2 of 2

**1. PRODUCT**  
oval cylinder

**PRODUCT TYPE**  
cylinder

---

## 2. TECHNICAL SPECIFICATION

Operating:	Mechanical operation
Construction:	outside or inside part
System:	round key profile
	1 electronic operated detainer, self powered
Material:	cylinder body: brass with various coatings
Dimension:	housing: 20x35x40 mm
Fixing:	2x M5x 60 mm
Intended use:	in combination with mortice locks on doors

---

## 3. DELIVERY

The delivery includes an installation instruction:  
M004121\_A

---

## 4. PERFORMANCES

A oval cylinder according this certificate fulfils the relevant requirements of BRL 3104.

A window- or door set, in which this oval cylinder is installed according the installation instructions of the certificate holder meets at least burglar resistance class (RC) 2 of NEN 5096 and EN 1627, if:

- the façade element or the (profile-)system from which the element is manufactured is delivered under a (KOMO-)quality approval with respect to the aspect burglar resistance, in which the actual window or door type is admitted and the herein mentioned conditions are fulfilled.

A window or door, in existing buildings, in which this oval cylinder is installed according the installation instructions of the certificate holder, meets the requirements of the Police Mark Save Housing (PKVW) - Existing Building, if:

- the other aspects of the façade element also comply with the applicable PKVW Protection directive (publication CCV).
-